


VESDA DESIGNATION LEGEND

PIPE 1 ← VESDA PIPE REFERENCE NUMBER
SECTION 1.1.1-1
HOLE REFERENCE NUMBER
VESDA PIPE SECTION REFERENCE NUMBER

- HSSD SAMPLE PIPING AND SAMPLE PORT (BELOW CEILING)
- HSSD SAMPLE PIPING AND SAMPLE PORT (ABOVE CEILING)
- FIRE ALARM CONDUIT (3/4-INCH).
SEE NOTES PROVIDED ON EACH PLAN FOR CIRCUITS.
- L1 - 1 PAIR #16; SLC/ALD LOOP (L1)
(SEE RACEWAY NOTES ON EACH FLOOR PLAN)
- AV1 - 1 PAIR #14; NOTIFICATION APPLIANCE CIRCUIT
(SEE RACEWAY NOTES ON EACH FLOOR PLAN)

HSSD PIPING LAYOUT - FLOOR 3

SCALE: 1/8" = 1'-0"



PROFESSIONAL SEAL (IF REVISION, APPLIES ONLY TO REVISED WORK)	AS BUILT — 08/28/13								74 FIRE ALARM SYSTEM 3RD FLOOR HSSD PIPING PLAN	DRAWN BY	DSV	DATE	08/28/13
										CHECKED BY	LDD	09/03/2013	
										APPROVED BY	MCD	09/03/2013	
										SCALE AS NOTED			
										DRAWING NO.			SHEET
UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY FACILITIES DIVISION									4B74E318				
ISSUE (PROGRESS, ESTIMATE, BID, CONSTRUCTION, CONFORMED, REVISION, RECORD)		REVISION NUMBER	DRAWN BY	CHECKED BY	APPR'D BY	DATE	REMARKS	PROJECT NO. FN9200		17 OF 20			
		—	DSV	LDD	MCD	08/28/13	AS BUILT FROM A/E RECORD DWGS						